MX60-D2

WEB Configuration Manual

For MX60-D Series Only: 1.00.00,Dec 23 2013(HW1.1)

MX60 Web Ver1.0 / Build Date 12/23/2013

Contents

D	n WEB	•••••
Premi	ise	
WEB	IE Browser	
Main Win	ndow (Terminal Status)	
Illustr	ration of Terminal Status Screen	
ser Admi	inistration	
Log/R	Report	
Illustr	ration of Access Log	
Auto 1	Refresh Log	
View	User List	
Illustr	ration of User List	····· <i>'</i>
Modif	fy User Record	
	fy User List in "View User List"	
	User	
Illustr	ration of Add New User	1
erminal .		12
	inal Status	
Termi	mai Status	
	ration of Terminal Status	
Illustr		13
Illustr Termi	ration of Terminal Status	13
Illustr Termi Illustr	ration of Terminal Statusinal Setup	
Illustr Termi Illustr Passw	ration of Terminal Statusinal Setupration of Terminal Configuration	
Illustr Termi Illustr Passw Illustr	ration of Terminal Statusinal Setupration of Terminal Configurationvord Setup	
Illustr Termi Illustr Passw Illustr Syster	ration of Terminal Status	
Illustr Termi Illustr Passw Illustr Syster Illustr	ration of Terminal Status	

	Illustration of Group List	24
	Illustration of Group Information	25
	Holiday Setup	26
	Illustration of Holiday Setup	26
	Door Setup	27
	Illustration of Door Setting	28
	Illustrations of Door 1 Setting in Door Setup	31
	Remote Control	34
	Illustrations of Door Status Monitoring/Security Bypass	35
	Event Handle	36
	Illustration of Event Handle	37
	Multi Badge Group	41
	Illustration of Multi Badge Group	41
Too	ols	42
	IP Camera	42
	Illustration of IP Camera	42
	Backup	42
	Restore	43
	Reboot	43
	Illustration of Reboot	43
	Upgrade Firmware	44
	Illustration of Upgrade Firmware	
	Reset	45
	Illustration of Reset	45

-WEB Configuration -

MX60-D2 WEB Configuration

♦ Logon WEB

MX60-D2 is with built-in HTTP server for using WEB IE Browser to connect MX60-D2 and execute the settings of MX60-D2.

♦ Premise

Please make sure the following points before your MX60-D2 settings:

- Your PC computer may build up a physical connection with MX60-D2, meanwhile, both of your computer and the MX60-D2 are within the same Network Segment.
- MX60-D2 has been installed and with power.
- Should the default IP address of MX60-D2 (192.168.0.66) has been occupied by other devices, you have to shut down all the other devices until the setting completed. Then a new IP address will be distributed to the MX60-D2.

♦ WEB IE Browser

- 1 · Start the WEB IE Browser first.
- 2 Enter the http:// and the IP address of MX60-D2 in the address bar. For example, enter the default IP address of MX60-D2: http://192.168.0.66.

Communication failure:

When no feedback from the MX60-D2, please check as below:

- Is the MX60-D2 installed properly, the local area network (LAN) connected well or the power connected fine? Try to use the "ping" command to test the communication status of MX60-D2 IP address by the following steps:
 - Open a MS-DOS window, or a command window;
 - Input your command: ping 192.168.0.66, For example: C:\user\tank>ping 192.168.0.66

If no any response, it indicated abnormal connection or the PC computer IP address in conflict or not match with MX60-D2 IP address (referring to next paragraph).

- If a PC computer with a Static IP/Fixed IP, the IP range should be defined between 192.168.0.1~ 192.168.0.65 or 192.168.0.67~192.168.0.254. So the PC computer IP may be compatible with the default IP address of MX60-D2, 192.168.0.66. Moreover, the Subnet Mask should be as 255.255.255.0 ∘
- To make sure both your PC computer and the MX60-D2 in the same Network Segment.

➤ Main Window (Terminal Status)

When installation completed and well connected with MX60-D2, the "Terminal Status" window will be pop-up. It will show after the following connection frequently as following illustration:

TERMINAL STATUS

Product Name :	SEMAC-D2(20000)
Serial No. :	036fe1(122022)
Firmware Version :	1.00.00,Dec 23 2013(HW1.1)
System Time :	02/11/2014 15:31:41
Terminal ID(MAC Address):	1(00:0e:e3:03:8f:e1)
IP Address :	192.168.2.55
Subnet mask :	255.255.255.0
Default Gateway :	192.168.2.1
Primary DNS:	168.95.1.1
Listen Port/Software IP(status):	2000/0.0.0.0(Offline)
Web Management Port :	80
Registered User :	0
Available User Capacity :	20000
Access/System Log Count:	0/10
Reader Type :	WG34
Anti-Pass-Back(Tolerance Timer) :	Disabled(0)
Anti-Duress :	Disabled
Next SEMAC(status):	0.0.0.0(Offline)

♦ Illustration of Terminal Status Screen

Browse the Function Bar left side:

► User Administration	n
Log/Report	Switch to the "Access Log" screen to check, search, export log reports
Auto Refresh Log	Press the button to refresh system to get new logs
View User List	Switch to the "User List" screen to
view User List	Search/Modify/Delete/Deactivate/Activate user data
Add User	Switch to the "User Record" screen and input user data on the "Add
Auu Osei	New User "screen
► Terminal	
Terminal Status	Switch to the "Terminal Status" screen (Main Window)
Terminal Setup	Switch to the "Terminal Configuration" screen to input data
Password Setup	Switch to the "WEB Logon Setting" and "Entrance Password" screen.
System Log	Switch to the "System Log" screen.
Clock Setup	Switch to the "System Clock Setup" screen.
► Access Control	
Time Set	Switch to the "Time Set" screen.
Time Zone Setup	Switch to the "Time Zone List" screen.
Group List	Switch to the "Group List" screen.
Holiday Setup	Switch to the "Holiday Setup" screen.
Door Setup	Switch to the "Door Setting" screen.
Remote Control	Switch to the "Door Status Monitoring" and "Security Bypass" screen.
Event Handle	Switch to the "Event Handle" screen.
Multi Badge Group	Switch to the "Multi Badge Group" screen.
► Tools	
IP Camera	Switch to the "IP Camera Configuration" screen.
Backup	Switch to Backup screen
Restore	Switch to Restore screen
Reboot	Switch to the "Reboot System" screen.
Upgrade Firmware	Switch to the "Firmware Upgrade" screen.
Reset	Switch to the "Reset" screen.
▶ Button	
Refresh	Refresh the WEB Status.

> User Administration

♦ Log/Report

Select"Access Control" on the Main Window, you'll see the "Access Log/Query and Export"screen as the following picture:

Access Log/Query and Export

No.	User ID	User Name	Date	Time	IN/OUT	Door	Note.
		No	Log Data				

Query and Export

Туре	Selection	Start Date	End Date			
● user ○ event	● Single ○ All	2014/02/06	2014/02/06			
User ID	Card No.(DEC)					
Export Type						
● Txt ○ XIs	Search	Export				

♦ Illustration of Access Log

► Query (BY)				
Туре	By User or Event			
Selection	Single or All			
Start / End Date	From – To Date period input			
User ID	Input User ID or Card No. (in Decimal format)			
Export Type	Text (txt) or Excel (xls) format			
► Access Records Illus	stration by Columns			
No.	Serial Number			
User ID	A system User ID assigned for the user to access door(s). Click the "User ID" to enter the page of "User Record" and "Modify User Record". ** The figure in the parentheses () after the "User ID" is indicated the user's Bypass TZ level as 1~10			
User Name	User name has registered to the current system			
Date	A date period allowed user(s) to access door(s)			
Time	A Time allowed for the User to get IN/OUT.			
IN/OUT	 2 Door/2 Way: IN: Open the door (1~2) by punching card at the outside of door reader to get IN records OUT: Open the door (1~2) by pressing push button inside of a door to get OUT records ※ The figure in the parentheses () after the "IN/OUT" record indicated APB (Anti Pass Back) level. 			
Door No.	Indicating the Door Number controlled by MX60-D2.			
Note	Show up the relative IN/OUT records automatically as Anti-Duress, Fire Alarmetc.			
the First Page	Back to the 1st IN/OUT records page.			
the Former10 pages	Forwarding 10 pages from the current IN/OUT records page.			
1 2 3N page	Change to any IN/OUT records page assigned.			
the Latter 10 pages	Backwards 10 pages from the current IN/OUT records page.			
the Last Page	Fly to the last IN/OUT records page directly.			

♦ Auto Refresh Log


Auto Refresh Log Wed Feb 05 2014 17:52:31 GMT+0800 (台北標準時間)

No.	User ID	User Name	Date	Time	IN/OUT Door	Note.

♦ View User List

Select"View User List" on the Main Window, you'll see the "User List" screen as the following picture:

User List



♦ Illustration of User List

► Search User By	
By "User ID"	Select "User ID" and Enter your "User ID" in the textbox to search.
By "Card	Select "Card No." and Enter your "Card No." in the textbox to search.
No."(DEC)	Select Card No. and Enter your Card No. In the textbox to search.
By "User Name"	Select "User Name." and Enter your "User Name" in the textbox to search.
Click "GO" Button	Start to search.

Steps:

- 1 · Enter your "User ID", "Card No." or "User Name" in the "blank textbox"
- 2 · Click button "GO" to search.

2 Chek but	ton oo to beaten.
► User List	
	Serial Number. Tick the box before the "Serial Number" and Click the
No.	button of "Activate", "Deactivate" or "Delete" to manage the
NO.	authorization of "Activate", "Deactivate" or "Delete" for selected users,
	multi-selection is allowed.
User ID	User's ID. Click the "User ID" to enter the "Modify User Record" page.
User Name	Display User Name in the system.
	Types of the User. Whenever the "User Type" is set up in the screen of
User Type	"Modify User Record", this page will display Normal User, Super User,
	Visitor, Guard Touring and Defense Card according to the setup.
Activo	Display the user's authorization status. Green Light indicated the user's
Active	door access authority is being activated, otherwise it is not activated.
P	When the user's Personal Password registered, this column will be with
r	Green Light.
C	When the user's card registered, this column will be with Green Light.
Bypass Level	Display the user's Time Zone level of Bypass from L1~L10.
the First Page	Back to the 1st page of "User List".
the Former10	Formula a 10 magas from the comment "Heart List" maga
pages	Forwarding 10 pages from the current "User List" page.
1 2 3N page	Change to any "User List" page assigned.
the Latter 10 pages	Backwards 10 pages from the current "User List" page.
the Last Page	Fly to the last "User List" page directly.
▶Button	
Activate	Activate the User's authorization.
Deactivate	Deactivate the User's authorization.
Delete	Delete the User's information registered.

♦ Modify User Record

Select "Modify User Record" on the Main Window, you'll see the "User Record" screen as following picture:

User Record

Modify User Record

User ID:	115	(1 ~ 20000)
Card No.:	1010151110	(DEC)
Name:	Katherine	(Max 31 chars.)
Expire Date Check:	Disable Enable	
	From 2014 ▼ (Y) 0	02 ▼ (M) 05 ▼ (D) 17 (H) 59 (M)
	To 2014 ▼ (Y) 0	02 ▼ (M) 05 ▼ (D) 17 (H) 59 (M)
Status:	 Activate	vate
User Type :	Normal User ▼	
Group :	1. Free Time Group	▼ 2. Disallowed Group ▼ 3. Disallowed Group ▼ 4. Disallowed Group ▼
Bypass TZ Level:	L1 ▼	
Personal Password:	(4 ~ 8 di	igits.)
Personal Confirm :		
		Save Delete

♦ Modify User List in "View User List"

User ID Self-define User ID from number 1~20,000 is allowed only.	
Manual input card no. in decimal format (when any card decoder in	stalled,
card no. can be read automatically)	
Name Input User's Name (max. 31 characters)	
Expire Date Check Enable or Disable user's authority expire date check	
Effective When "Expire Date Check" enabled. It requires to enter a period of	date
From ~To time.	
Status "Activate" or "Deactivate" user access authority for system	
Card Types of the User. The "Drop Down Menu" will list out card	s for
Normal User , Super User, Visitor, Guard Touring, Defense Card	d ,
Manager Card-Add and Manager-Card-Delete as your choice. The	
Respective definitions are as below:	
Normal User: System default type for common users.	
Super User Card: Not constrained by APB (Anti Pass Back) rule.	
Visitor Card: Program visitor cards with certain date access permis	sion
(expired date check)	
User Type Guard Touring Card: Door won't open when Guard Touring card	
punched but log will be kept on system.	
Defense Card: When the card sweeps the door, all the doors will ac	tivate
Access Control at once. Any type of cards cannot ac	ccess
the door until the Defense Card punch again to	
restore normal functions.	
Manager Add-Card: Card will be added when Add-Card scanned	
Manager Delete-Card: Card will be deleted when Delete-Card sca	nned
Each user can be assigned to 4 different groups. All of the group nar	nes
Group existed will be automatically listed out by the "Drop Down Menu" f	or your
choice. "Free Time Group" is a "Default Group".	
The "Bypass Time Zone Level" of each user is from L1~L10.	
When user's Bypass TZ level >Door Bypass TZ Level, User may ac	cess
door by card only. When user's Bypass TZ level < Door's Bypass TZ	Z level,
user should access the door by door's setup bypass level.	
Personal Password 4~8 digits allow only	
Personal Confirm Reconfirm Personal Password.	
▶Button	
Previous Modify previous user record.	
Save Save the modified user record.	
Delete existing user record.	
Next Modify next user record.	

♦ Add User

Select"Add User" on the Main Window, you'll see the User Record "screen for Add New User as the following picture:

Add New User	
REG:	Single Continuous Amount:
User ID:	(1 ~ 20000)
Card No.:	(DEC)
Name :	(Max 31 chars.)
Expire Date Check:	Disable Enable
	From 2014 V (Y) 02 V (M) 06 V (D) 15 (H) 0 (M)
	To 2014 V (Y) 02 V (M) 06 V (D) 15 (H) 0 (M)
Status :	Activate Deactivate
User Type:	Normal User V
Group:	1. Free Time Group ♥ 2. Disallowed Group ♥ 3. Disallowed Group ♥ 4. Disallowed Group ♥
Bypass TZ Level:	L1 V
Personal Password :	(4 ~ 8 digits.)
Personal Confirm :	
	Save

♦ Illustration of Add New User

▶ User Record	
	Single: Only one user can be registered each time.
REG	Continuous: It allows you to register 1~20000 users continually. You
KEG	may input required q'ty in the textbox of Amount. However,
	only the serial number is accepted and supported.
User ID	Self-define User ID from number 1~20,000 is allowed only.
Card No.	Manual input card no. in decimal format (when any card decoder
Card No.	installed, card no. can be read automatically)
Name	Input User's Name (max. 31 characters)
Expire Date Check	Enable or Disable user's authority expire date check
Effective	When "Expire Date Check" enabled. It requires to enter a period of date
From ~To	time.
Status	"Activate" or "Deactivate" user access authority for system
	Card Types of the User. The "Drop Down Menu" will list out cards for
	Normal User , Super User, Visitor, Guard Touring, Defense Card ,
	Manager Card-Add and Manager-Card-Delete as your choice. The
	Respective definitions are as below:
	Normal User: System default type for common users.
	Super User Card: Not constrained by APB (Anti Pass Back) rule.
	Visitor Card: Program visitor cards with certain date access permission
Han Tuna	(expired date check)
User Type	Guard Touring Card: Door won't open when Guard Touring card
	punched but log will be kept on system.
	Defense Card: When the card sweeps the door, all the doors will activate
	Access Control at once. Any type of cards cannot access
	the door until the Defense Card punch again to
	restore normal functions.
	Manager Add-Card: Card will be added when Add-Card scanned
	Manager Delete-Card: Card will be deleted when Delete-Card scanned
	Each user can be assigned to 4 different groups. All of the group names
Group	existed will be automatically listed out by the "Drop Down Menu" for
	your choice. "Free Time Group" is a "Default Group".
	The "Bypass Time Zone Level" of each user is from L1~L10.
Bypass TZ Level	When user's Bypass TZ level >Door Bypass TZ Level, User may access
bypass 12 Level	door by card only. When user's Bypass TZ level < Door's Bypass TZ
	level, user should access the door by door's setup bypass level.
Personal Password	4~8 digits allow only
Personal Confirm	Reconfirm Personal Password.
▶Button	
Save	Save user records.

> Terminal

♦ Terminal Status

Select and Click" Terminal Status" on the left side of the Main Window, you'll see the "Terminal Status" screen. This screen is the Main Window for Logon. It displays the current Terminal Status and relative information of WEB setup, referring to the following picture:

TERMINAL STATUS

Product Name :	SEMAC-D2(20000)
Serial No. :	038fe1(122022)
Firmware Version :	1.00.00,Dec 23 2013(HW1.1)
System Time :	02/11/2014 15:31:41
Ferminal ID(MAC Address):	1(00:0e:e3:03:8f:e1)
P Address:	192.168.2.55
Subnet mask :	255.255.255.0
Default Gateway :	192.168.2.1
Primary DNS:	168.95.1.1
Listen Port/Software IP(status) :	2000/0.0.0.0(Offline)
Veb Management Port :	80
Registered User :	0
Available User Capacity :	20000
Access/System Log Count :	0/10
Reader Type :	WG34
Anti-Pass-Back(Tolerance Timer) :	Disabled(0)
Anti-Duress :	Disabled
Next SEMAC(status):	0.0.0.0(Offline)

♦ Illustration of Terminal Status

► Terminal Status	
Product Name	Model Number of MX60-D2
Serial No.	Serial Number of MX60-D2
Firmware Version	Firmware and Hardware Version of MX60-D2
System Time	System Time of MX60-D2
Terminal ID	Terminal ID and MAC address of MX60-D2
(MAC Address)	Terminal ID and MAC address of MA00-D2
IP Address	Current IP address of SECMAC-D2
Subnet mask	Subnet mask of MX60-D2
Default Gateway	Default Gateway address of MX60-D2
Primary DNS	Primary DNS address of MX60-D2
Listen Port/Software	Listen Port and Networking Software IP address
IP(status)	(status : Online or Offline)
WEB Management Port	WEB communication number of MX60-D2
Registered User	Registered user number of MX60-D2
	Available Capacity of MX60-D2 to register users;
Available User Capacity	Available user number(s) to be registered=
	Sum (20000)—Registered user(s)
Access/System Log Count	The Sum from access and system logs of MX60-D2
Reader Type	Indicated connected reader format (default is WG34)
Anti-Pass-Back	Current APB status (Enable or Disable) on MX60-D2, indicating
(Tolerance Time)	with (APB Tolerance Time)
Anti-Duress	Current Anti-Duress status (Enable or Disable) on MX60-D2.
	IP Address of Next MX60-D2 which interaction with first APB
Next MX60(status)	(anti pass-back) function and Fire Alarm door emergency open.
	Also indicating with connectivity status (Online or Offline)

♦ Terminal Setup

Select and Click"Terminal Setup" on the left side of the Main Window, you'll see the "TERMINAL CONFIGURATION", referring to the following picture:

Terminal Configuration

Terminal Setting :	Terminal ID : 1
	*IP Address: 192 . 168 . 2 . 68
	*Subnet Mask: 255 . 255 . 0
	*Gateway: 192 . 168 . 2 . 1
	*DNS Server: 168 . 95 . 1 . 1
Software:	*TCP Port(Software Used) : 2000
Web Language :	English V
Anti Pass Back :	○ Enable ○ Anti Follow Disable
	Tolerance Timer 0 (Minute, Maximum 65535, 0 means No Tolerance)
Anti Duressed :	○ Enable Disable
	Password • (Max 3 digits,default is 9)
WEB Managemant Port :	Http Port: 68
Next SEMAC(for APB):	IP Address: 0 . 0 . 0
Fast Reg Card Mode:	○ Enable Disable
	Terminal may need to restart after configuration saved.
	SAVE

♦ Illustration of Terminal Configuration

► Terminal Conf	figuration
Terminal	
Setting:	Setting Terminal ID for current MX60-D2. Default ID=1, max. 65,535
Terminal ID	(Terminal ID should not be duplicated in one system)
IP Address	Setting IP Address of MX60-D2.
Subnet Mask	Setting Subnet Mask of MX60-D2
Gateway	Setting Default Gateway of MX60-D2
DNS Server	Setting the DNS Server IP Address of MX60-D2. Default DNS Server IP
IP Address	Address is 168.95.1.1.
▶ Software	
TCP Port	Setting a TCP Port for Software to communicate with MX60-D2.
(Software Used)	Default TCP Port No. is 2000
C - 64 ID	For setting the Software IP to communicate with MX60-D2
Software IP	Default Software IP is 0.0.0.0.
▶ Web Language	e
English	When you choose the" English" language from the "Drop Down Menu",
Liigiisii	the WEB page of MX60-D2 will be switched to "English" interface.
	When you choose the" Chs" language from the "Drop Down Menu",
Chs	the WEB page of MX60-D2 will be switched to "Simplified Chinese"
	interface.
	When you choose "Others" from the "Drop Down Menu", the WEB page of
Others	MX60-D2 will be switched to "Traditional Chinese" interface or other
	languages.
► Anti Pass Bacl	
Enable	Tick this circle to enable the "APB" (Anti Pass Pack) function.
Anti Follow	Automatically set all door(s) with APB level: Entry (IN): 1, Exit (OUT):2.
	User should access door only from Entry side then exit from Exit side.
Disable	Tick this circle to disable the "APB" (Anti Pass Pack) function.
	Set a time that system will be restored to original status after "APB"
	triggered.
Tolerance Time	The unit of time can be $0\sim65535$ (minute).
	For value set to "0" which indicated APB function will not be restored to
	normal after certain time until manually disable "APB" function.
.	(Default value=0)
► Anti Duress	
Enable	Tick this circle to enable the "Anti Duress" function.
Disable	Tick this circle to disable the "Anti Duress" function.
Password	Set a set of password for "Anti Duress" function.
	Default value = 9, max. 3 digits.
► WEB Manage	
Http Port	Set your WEB communication port for MX60-D2, default value=80.
► Next MX60(fo	
IP Address	Set IP address for Next MX60-D2. All the APB level setting from first
Dutton	MX60-D2 will be copied to next MX60-D2.
► Button	Cave the Terminal configuration settings
Save	Save the Terminal configuration settings.

♦ Password Setup

Select "Password Setup" on the left side of the Main Window, you'll see the "WEB Logon Setting/Entrance Password" screen, referring to the following picture:

WEB Logon Setting

Administrator WEB Logon User Name :		(47 Char. Max)
Administrator WEB Logon Password :	••••	(35 Char. Max)
Operator WEB Logon User Name :	user	(47 Char. Max)
Operator WEB Logon Password :	••••	(35 Char. Max)
USER WEB Logon User Name :	user0	(47 Char. Max)
USER WEB Logon Password :	••••	(35 Char. Max)
	SAVE	
Entrance Password		
Administrator Password :	(4 ~ 8 digits.)	
Common Password :	12345 (4 ~ 8 digits.)	
	SAVE	

♦ Illustration of WEB Logon Setting/Entrance Password

▶ WEB Logon Setting	
Administrator WEB Logon	Input the required Administrator's logon user name for WEB
User Name	management, max. 47 characters, default value: "admin".
Administrator WEB	Input the required Administrator's logon password for WEB
Logon Password	management, max. 35 digits, default value: "admin".
Operator WEB Logon	Input the required Operator's logon user name for WEB
User Name	management, max. 47 characters, default value: "user".
Operator WEB Logon	Input the required Operator's logon password for WEB
Password	management, max. 35 digits, default value: "user".
User WEB Logon User	Input the required User's logon user name for WEB
Name	management, max. 47 characters, default value: "user0".
Han WED I and Daniel	Input the required User's logon user name for WEB
User WEB Logon Password	management, max. 35 digits, default value: "user0".
The Administrator, Operator an	d User have their respective authorizations, referring to the
following "Authorization Table	, [,] ,
▶Button	
Save	Save all the WEB Logon Settings.
▶ Entrance Password	
	Set your "Common Password" here. Meanwhile, you have
	to select "001 Any Time "for "Common Password Time
	Zone "simultaneously to support this setting (for example:
Common Password	Door Setup→Door Setting→Click "Door1"→Door 1 Setting→
	Select "Common Password Time Zone "→ Select "001 Any
	Time "from the "Drop Down Menu").
	Default value: "1234".
▶Button	
Save	Save the Password setting.

Authorizations Table (" \bullet " = Access Permission)

WEB Function	Administrator User Name: admin Password : admin	Operator User Name: user Password : user	User User Name: user0 Password : user0
Upgrade Firmware	•		
Password Setup	•		
Terminal Setup	•		
Door Setup	•		
Event Handle	•		
Reboot	•		
Clock Setup	•		
Reset	•		
Upgrade Firmware	•		
Password Setup	•		
Terminal Setup	•		
User Data	•	•	
Time Set	•	•	
Time Zone Setup	•	•	
Group List	•	•	
Holiday Setup	•	•	
Multi Badge Group	•	•	
Remote Control	•	•	
Access Log	•	•	•
View User List	•	•	•
Terminal Status	•	•	•
System Log	•	•	•
IP Camera	•	•	•

♦ System Log

Select "System Log" on the left side of the Main Window, you'll see "System Log "screen as the following picture:

System Log

No.	Date	Time	Description
1.	09/15/2009	13:46:44	Disconnected by Server
2 .	09/15/2009	13:43:39	PC Server Connected
3.	09/15/2009	13:43:06	Connect PC Server Fail
4.	09/15/2009	13:39:51	Set Date(09/09/15)Day(2)Time(13:39:52) via Software
5.	09/15/2009	13:39:50	PC Server Connected
6.	09/15/2009	13:30:37	Connect PC Server Fail
7.	09/15/2009	13:29:51	System Warm Start
8.	09/15/2009	13:29:50	System Terminal Setup from Web
9.	09/15/2009	13:29:41	System Warm Start
10 .	09/15/2009	13:29:40	System Terminal Setup from Web
11 .	09/15/2009	13:16:08	Connect PC Server Fail
12 .	09/15/2009	13:15:27	Disconnected by Server
13 .	09/15/2009	13:14:01	PC Server Connected
14 .	09/15/2009	13:12:59	Connect PC Server Fail
15 .	09/15/2009	13:12:18	Disconnected by Server
16 .	09/15/2009	13:11:28	PC Server Connected
17 .	09/15/2009	13:08:52	Connect PC Server Fail
18 .	09/15/2009	13:08:11	Disconnected by Server
19 .	09/15/2009	13:07:39	PC Server Connected
20 .	09/15/2009	12:00:00	Connect PC Server Fail
Total 76	Record(s)		<< <u>First</u> Prev 10 1 <u>2 3 4</u> Next 10 <u>End</u> >>

♦ Illustration of System Log

► System Log	
No.	Serial Number of the log
Date	Date of the log
Time	Time of the log
Description	Description of the system operation records
	city: 1536 entries, for checking by authorized person(s) only, no logs export
provide.	

♦ Clock Setup

Select and Click "Clock Setup" on the left side of the Main Window, you'll see the "System Clock Setup" screen, referring to the following picture:

SYSTEM CLOCK SETUP

	time.windows.com		Recommend: time.windows.com or time.nist.go
ime Zone:	(GMT+08:00) China, Hong Kong, Aust	tralia Western	v
			_
		I SAV	El
		SAV	E
		SAV	E
	New Date : 0		(mm/dd/yyyy)

♦ Illustration of System Clock Setup

▶ Time Server			
Disable	Tick this circle to shut up the Time Server network connection.		
Enable	Tick this circle to start the Time Server network connection.		
Time Zone	The "Drop Down Menu" offers you all the Time Zones available up		
Time Zone	to your option, default time zone : (GMT)England.		
"Save" button	Save the Time Server Settings and adjust the time.		
When enable the "Tin	When enable the "Time Server", please key in the IP address or http:// of the "Time Server".		
Then select the requi	Then select the required Time Zone and Save it to connect the "Time Server" for a time		
adjustment.			
New Date	The date of networked PC computer. You may adjust the date to your		
	requirement as the format of "mm/dd/yyyy".		
New Time	The date of networked PC computer. You may adjust the time to your		
New Time	requirement as the format of "hh:mm:ss".		
"Save" button	Save the configuration of this page and upgrade the date/time for the		
Save button	networked PC computer.		

> Access Control

♦ Time Set

Select and Click "Time Set" on the left side of the Main Window, you'll see the "Time Set" screen, referring to the following picture:

Time Set

000	00:00 ~ 00:00		001	00:00 ~ 23:59	
002	04:00~17:00	DELETE	003	18:00~23:00	DELETE
004	02:00~05:30	DELETE	005	15:00~19:00	DELETE
006	16:00~19:00	DELETE	007	07:00~16:00	DELETE
800	17:30~21:30	DELETE	009	03:45~09:30	DELETE
010	10:00~14:00	DELETE	011	09:00~17:00	DELETE
012	17:00~22:00	DELETE	013	00:00~13:00	DELETE
014	19:00~23:00	DELETE	015	07:30~15:00	DELETE
016	16:00~20:00	DELETE	017	12:58~19:56	DELETE
018	12:58~18:59	DELETE	019	02:00~08:00	DELETE
020	03:00~05:00	DELETE	021	07:00~13:00	DELETE

Time Set: 022 From 00 H: 00 M To 23 H: 59 M SET

♦ Illustration of Time Set

► Time Set List		
Time Set List	It will display all the configured time set(s).	
Time Set List	The System Default Time sets are: 00:00~00:00 and 00:00~23:59.	
	Select your time set serial number. The "Drop Down Menu" offers you	
Time Set	all the options for your choice, max. 255 time sets allowed. System built-in	
	values are "000" and "001".	
	Input a time set period, for example: 8:00am to 17:00pm as one period, then	
From ~ To	Time Set: 002 From 00 H: 00 M To 23 H: 59 M SET	
	It is the same way to the others.	
▶ Button		
Delete	Delete an existing "Time Set".	
Set	Add a new "Time Set".	

♦ Time Zone Setup

Select and Click"Time Zone Setup" on the left side of the Main Window, you'll see the "Time Zone List" screen as below:

Time Zone List


Time Zone List:					
000	Deactivate		001	Any Time	
002	2	DELETE	003	<u>3</u>	DELETE
004	4	DELETE	005	<u>5</u>	DELETE

Time Zone ID: 006 SET


♦ Illustration of Time Zone List

► Time Zone List		
	Display all the Time Zone(s) existing. Click the Time Zone name(indicated	
Time Zone List	as the Time Zone Name example) to enter its Time Zone Information Screen.	
Time Zone ID	Select your Time Zone Serial Number from the "Drop Down Menu", system	
Time Zone ID	built-in numbers as "000" and "001", max. 120 Time Zones allowed.	
Time Zone	Click the name of Time Zone (for example : 2, as below picture) to enter the	
Name	"Time Zone Information" screen for modification.	
▶ Button		
Delete	Delete an existing Time Zone.	
Set	Enter the Time Zone Information screen.	

X Example of "Time Zone Information" screen to show how to set the daily door access and card punching authorized Time Set from Monday to Sunday and Holidays:



♦ Illustration of Time Zone Information



♦ Group List

Select" Group List" on the left side of the Main Window, you'll see the "Group List" screen as below:

Group List

Group	List:					
	000	Disallowed Group		001	Free Time Group	
	002	2	DELETE	003	<u>3</u>	DELETE
	004	4	DELETE			

Group ID: 005 V SET

♦ Illustration of Group List

▶ Group List					
	Display all the Groups configured. Click the Group's name to enter its				
	"Group Information "as below:				
	(for example: click Group Name"4" as picture)				
	Group Information				
Group List	Allowed Door: 1. 000 Deactivate 2. 000 Deactivate Save Cancel				
	Select your "Group ID" by serial number, default values : 000 \ 001.				
Group ID	The "Drop Down Menu "offers you all the serial number of Group ID as				
	options, max. 255 groups allowed.				
▶ Button					
Delete	Delete a Group ID.				
Set	Enter the "Group Information" screen.				

This is a screen to configure the door(s) of a Group ID, referring to the following picture:

Group Information

Allowed Door :	Time Zone ID :
□ 1.	000 Deactivate 🗸
2 .	000 Deactivate 🗸
	Save Cancel


♦ Illustration of Group Information

► Allowed Door		
Door 1	Tick the box of Door 1, then the user(s) assigned to the Group can be access	
Door 1	Door 1 within the "Time Zone ID" indicated, otherwise prohibited.	
Door 2	Tick the box of Door 2, then the user(s) of this Group can access Door 2 within	
D00F 2	the "Time Zone ID" indicated, otherwise prohibited.	
Tim Zone ID	The "Drop Down Menu" displays all the "Time Zones" configured in the "Time	
Tim Zone ID	Zone Setup" for option.	
▶ Button		
Save	Save the "Group Information".	
Cancel	Cancel or Modify the "Group Information"	

♦ Holiday Setup

Select" Holiday Setup" on the left side of the Main Window, you'll see the "Holiday setup" screen as below:

Holiday setup



♦ Illustration of Holiday Setup

► Holiday Setup		
Month	Select a month from the "Drop Down Menu".	
Date	Select a date from the "Drop Down Menu".	
▶ Button		
Set	Add a new Holiday.	
Delete	Delete a Holiday.	

♦ Door Setup

Select and Click"Door Setup" on the Main Window, you'll see the "Door setting" screen as below:

Door Setting

L10 First Admin Card IN TZ 000 L9 2/3 Badge+Admin P TZ 0(2)/0(2 L8 2/3 Badge+Personal P TZ 0(2)/0(2	000
L9 2/3 Badge+Admin P TZ 0(2)/0(2	2) 0(2)/0(2)
L8 2/3 Badge+Personal P TZ 0(2)/0(2	0(2)/0(2)
	., 5(2).5(2)
L7 2/3 Badge TZ 0(2)/0(2	2) 0(2)/0(2)
L6 Card+Admin P TZ 0/0	0/0
L5 Admin P TZ 0/0	0/0
L4 Card+Personal P TZ 0/0	0/0
L3 PTZ 0/0	0/0
L2 Card Only TZ 0/0	0/0
L1 Card or P TZ 1/1	1/1
Lock Release TZ 000	000
Exit Button TZ 001	001
APB IN/OUT 0/0	0/0
Multiple Interlocking N	N
Remote Grant Needed N	N
Open Delay Time 10	10
Door Open Delay Time 10	10
Still Open Delay Time 0	0
Degrade Mode Deactive	ate Deactivate
Log Recorded/Sensor Mode Y/None	Y/None

♦ Illustration of Door Setting

▶ Door Setting			
L10 : First Admin	Display the First Admin Card IN Time Zone from Door 1 to Door 2.		
Card IN TZ	Display the Prist Admini Card IN Time Zone from Door 1 to Door 2.		
L9: 2/3 Badge	Display the Multiple Badge+ Admin Password Time Zone from Door 1 to		
+Admin PTZ	Door 2, accompanied by a Double or Triple verifications.		
L8: 2/3 Badge	Display the Multiple Badge +Personal Password Time Zone from Door 1		
+Personal PTZ	to Door 2, accompanied by a Double or Triple verifications.		
I 7: 2/2 Radge T7	Display the Multiple Badge Time Zone from Door 1 to Door 2,		
L7: 2/3 Badge TZ	accompanied by a Double or Triple verifications.		
L6: Card + Admin P	Display the Cord Admin Deserved Time Zone from Deep 1 to Deep 2		
TZ	Display the Card +Admin Password Time Zone from Door 1 to Door 2.		
L5: Admin PTZ	Display the Admin Password Time Zone from Door 1 to Door 2.		
L4: Card + Personal	Display the Card +Personal Password Time Zone from Door 1 to Door 2.		
TZ	Display the Card +Fersonal Fassword Time Zone from Door 1 to Door 2.		
L3: Common	Display the Common Password Time Zone from Door 1 to Door 2		
Password TZ	Display the Common Password Time Zone from Door 1 to Door 2.		
L2: Card Only TZ	Display the Card Only Time Zone from Door 1 to Door 2.		
L1: Card or	Display the Card or Common Password Time Zone from Door 1 to Door		
Common Password	2.		
TZ	2.		
Lock Release TZ	Display the Lock Release Time Zone from Door 1 to Door 2.		
Exit Button TZ	Display the Exit Button TZ from Door 1 to Door 2.		
APB IN/OUT	Display the Anti Pass Back Level from Door 1 to Door 2, APB level :		
AI B IIV/OUI	0-255 for door IN/OUT.		
Multiple-Door	Display the Dual Interlocking function from Door 1 to Door 2, "Enabled"		
Interlocking	or "Disabled".		
Remote Grant	Display the Remote Grant function from Door 1 to Door 2, "Enabled" or		
Needed	"Disabled".		
Lock Release Time	Display the Door Lock Release Time from Door 1 to Door 2, 1 – 65535		
(Open Delay Time)	seconds allowed and 10 seconds = default.		
Door Open Delay	Display the Door Open Delay Time from Door 1 to Door 2, 10 seconds =		
Time	default.		
Still Open Delay	Set a time period (0~255 seconds) to adjust door sensor/relay reaction		
Time	Set a time period (0~255 seconds) to adjust door sensor/reray reaction		

	T		
	Set door access method with: Deactivated (Default)/Registered/FC/All		
Degrade Mode	Deactivated =Default=Access Authority based on normal setup.		
	Registered : Users who have been registered to system can access the		
	door		
	FC : Users may access door by punching card programmed with Facility		
	Code and preset on MX60-D2 system. MX60-D2 system will verify only		
	FC (Facility code).		
	Uni Setup		
	Wiegand Input :	Format 34 Bits V (Default: 34 Bits)	
	Connection with Software :	TCP Mode Realtime(Client) V (Default: Realtime Mode)	
	Access Log Password :	● ON ○ OFF	
	Facility Code(2 bytes in Decimal) :	1: 0 2: 0 3: 0 4: 0 5: 0	
		6: 0 7: 0 8: 0 9: 0 10: 0	
	DEC/HEX :	● DEC ○HEX	
	Card Format:		
	LOGO_CONTROLLER:	● Default ○ OFF	
		SAVE	
	All: User may access door	by any kind of RFID cards	
Log	Display the Access Log to be Recorded or Ignored from Door 1 to Door		
Recorded/Sensor			
Mode	2, and the Door Sensor Mode.		
Door 1 (on top)	Click "Door 1" to enter the "Door 1 Setting" screen.		
Door 2 (on top)	Click "Door 2" to enter the "Door 2 Setting" screen.		

Door 1 Setting

First Admin Card IN Time Zone :	000 Deactivate 🗸
Multiple Badge+Admin Password Time Zone :	000 Deactivate \checkmark Double \checkmark 000 Deactivate \checkmark Double \checkmark
Multiple Badge+Personal Password Time Zone :	000 Deactivate ✔ Double ✔ 000 Deactivate ✔ Double ✔
Multiple Badge Time Zone :	000 Deactivate ✔ Double ✔ 000 Deactivate ✔ Double ✔
Card+Admin Password Time Zone :	000 Deactivate ✓
Admin Password Time Zone :	000 Deactivate ✓
Card+Personal Password Time Zone :	000 Deactivate ✓
Password Time Zone :	000 Deactivate ✓
Card Only Time Zone :	000 Deactivate ✓
Card or Password Time Zone :	001 Any Time ✓ 001 Any Time ✓
Lock Release Time Zone :	000 Deactivate V First Card No Need V
Exit Button TZ:	001 Any Time 💙
Anti Pass Back Level :	IN : 0 OUT : 0 (0 - 255)
Remote Grant Only:	Disabled >
Lock Release Time :	10 Sec (1 - 65535, 10 = default)
Door Open Delay Time :	10 Sec (1 - 65535, 10 = default)
Access Log:	Recorded V
Door Sensor Mode:	N/A 💙
Still Open Delay Time :	0 (1-255,0=default)
Degrade Mode :	Deactivate V

Set

2

♦ Illustrations of Door 1 Setting in Door Setup

▶ Door 1 Setting	
First Admin Card IN Time Zone	Set up the time zone of First Administrator's Card to open the door as the bypass time zone of Door (default—"000 Deactivate"). When this time zone is chosen, the user can only use the card of Administrator to scan/sweep the controller first and the other users may enter Door 1. Nobody may enter without using this First Admin Card to scan the controller of Door in advance. X Should the user's bypass time zone level is L10, he/she may access by scanning the card and enter the Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.
Multiple Badge +Admin Password Time Zone	Set up the Multiple Badge + Administrator Password time zone as the bypass time zone of Door (default—"000 Deactivate"). Before setting this time zone, you must choose the function of " Multi Badge Group "to come to the "Multi Badge Group " screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards and the Administrator's password to enter the Door successfully. No any order limitation for scanning the cards first or enter the password first. You may scan the cards first then enter the password, or in reverse order. X Should the user's bypass time zone level is L9~L10, he/she may access by scanning the card and enter the Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.
Multiple Badge +Personal Password Time Zone	Set up the Multiple Badge + Personal Password time zone as the bypass time zone of Door (default–000 Deactivate"). Before setting this time zone, you must choose the function of "Multi Badge Group" to come to the "Multi Badge Group" screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards and the Personal password to enter the Door successfully. No any order limitation for scanning the cards first or enter the password first. You may scan the cards first then enter the password, or in reverse order. However, the order of personal passwords will make differences. For example, there are two cards + passwords belonged to A and B. Should A card be scanned first, A has to enter his/her password first. Password B is not allowed to be entered before Password A. X Should the user's bypass time zone level is L8~L10, he/she may access by scanning the card and enter the Door directly; however when the bypass time zone setup of Door is "Lock Release Time Zone", the user may access directly without any limitation.

Multiple Badge Time Zone	Set up the Multiple Badge time zone as the bypass time zone of Door (default—"000 Deactivate"). Before setting this time zone, you must choose the function of "Multi Badge Group" to come to the "Multi Badge Group" screen and give the user ID in this time zone, max. 3 user IDs allowed; the user needs both 2 or 3 user ID cards to enter the Door successfully. No any order limitation for scanning the cards ** Should the user's bypass time zone level is L7~L10, he/she may access by scanning the card and enter the Door directly; however when the bypass time zone setup of Door is "Lock Release Time Zone", the user may access directly without any limitation.
Card +Admin Password Time Zone	Set up the Card + Admin Password time zone as the bypass time zone of Door (default—" 000 Deactivate"). The user has to scan the card and enter the Admin Password to access Door. No any order limitation for scanning the cards first or enter the password first. X Should the user's bypass time zone level is L6~L10, he/she may access by scanning the card and enter the Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.
Admin Password Time Zone	Set up the Admin Password time zone as the bypass time zone of Door (default—"000 Deactivate"). The user has to enter the Admin Password to access Door. X Should the user's bypass time zone level is L5~L10, he/she may access by scanning the card and enter Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.
Card +Personal Password Time Zone	Set up the Card+ Personal Password time zone as the bypass time zone of Door (default—" 000 Deactivate"). The user has to scan the card and enter the Personal Password to access Door. No any order limitation for scanning the cards first or enter the password first. X Should the user's bypass time zone level is L4~L10, he/she may access by scanning the card and enter Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.
Password Time Zone	Set up the Common Password time zone as the bypass time zone of Door (default—"000 Deactivate"). The user has to enter the Common Password to access Door. X Should the user's bypass time zone level is L3~L10, he/she may access by scanning the card and enter Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.

Card Only Time Zone	Set up the Card Only time zone as the bypass time zone of Door (default –"000 Deactivate"). The user has to scan the card to access Door. X Should the user's bypass time zone level is L2~L10, he/she may access by scanning the card and enter Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.	
Card or Password Time Zone	Set up the Card or Common Password time zone as the bypass time zone of Door (default as " 001 Any Time"). The user has to scan the card or enter the Common Password to access Door. X Should the user's bypass time zone level is L1~L10, he/she may access by scanning the card and enter Door directly; however when the bypass time zone setup of Door is" Lock Release Time Zone ", the user may access directly without any limitation.	
Lock Release Time Zone	Set up the Lock Release time zone as the bypass time zone of Door (default—"000 Deactivate"). The user needs no any verification to access Door; however, if the First Card" setup is "Needed", the use has to scan a "First Card" in advance to activate the "Lock Release Time Zone" function.	
Exit Button TZ	Set up the Exit Button time zone as the bypass time zone of Door, supporting "OUT "for Door only (default as " 001 Any Time").	
Anti Pass Back Level	Set up the Anti Pass Back Level of " IN " and " OUT " for Door, level 0~255.	
Dual Interlocking	Disable or Enable the "Dual Interlocking" function. Upon this function enabled, the user enters Door and cannot enter the other door until Door close.	
Remote Grant	Disable or Enable the "Remote Grant" access control function. Upon this function enabled, the Software will take a remote control over the door's open or close.	
Lock Release Time	Set up the "Lock Release Time", default as 10 seconds.	
Door Open Delay Time	Set up "Door Open Delay Time", default as 10 seconds.	
Access Log / Door Sensor Mode	Set up "Ignored" or "Recorded" the Access Log (default as "Recorded") Set up Door Sensor Mode, options for "Normal Open/Close" or "Circuit Short/Open" (default as "Normal Open/Close"). Should it is "Circuit Short/Open" selected, the Door Setting will display "Circuit Short" when the door is in short circuit or broken.	
Still Open Delay Time	Set a time from 0~255 seconds for adjusting door sensor/relay reaction time difference	
Degrade Mode	Select system verification mode: Deactivated/Registered/FC/ALL	

Remarks: Same setting for door 1 ~Door 2

♦ Remote Control

Select and Click "Remote Control" on the left side of the Main Window, you'll see the "Door Status Monitoring /Security Bypass" screen as below:

Door Status Monitoring Door 1 Door State Fire Alarm Detection off Defense State **Security Bypass** Door 1 Door 2 State Normal Normal □ Door 1 □ Door 2 □ SELECT ALL CANCEL ALL Pulse Open Door Force Close Back To Normal Force Open Emergency Open All Door Emergency Close All Door Fire Alarm Detection ON Fire Alarm Detection OFF Alarm OFF

♦ Illustrations of Door Status Monitoring/Security Bypass

▶ Door Status Monitoring	
Door Status	Display the most updated status from Door 1 to Door 2. No light Displayed indicated no response Green light indicated door closed Yellow light indicated door opened Red light indicated abnormal status (for example, short circuit, intruded, door opened too long, and so on)
Fire Alarm Detection	Display whether the "Fire Alarm Detection "function enabled or not.
Defense State	Display whether the "Defense State "function enabled or not.
► Security Bypass	
State	Display the "Security Bypass State" from Door 1 to Door 2, Normal/Force Open/Force Close.
Door 1	Tick the box of Door 1 to monitor the Security Bypass of Door 1.
Door 2	Tick the box of Door 2 to monitor the Security Bypass of Door 2.
Select All	Click this button and tick all the boxes from Door 1 to Door 2.
Cancel All	Click this button and cancel all the ticks of the boxes before Door 1 ~ Door 2.
Pulse Open Door	Click this button to open the door(s) remotely for all the door(s) ticked. This function works when the Security Bypass state is normal.
Force Close	Click this button to make a force close on the door(s) remotely for all the door(s) ticked. Hence the state(s) of all the door(s) ticked will display "Force Close". Even the RFID card scanned through the door(s), you may not access the door(s).
Back to Normal	Click this button to remotely restore all the door(s) ticked back to normal Security Bypass status.
Force Open	Click this button to make a force open on the door(s) remotely for all the door(s) ticked. Hence the state(s) of all the door(s) ticked will display "Force Open " and the door(s) will stay at "Lock Release" status.
Emergency Open All Door	Click this button to make a force open on all the door(s) remotely and the door(s) will stay at "Lock Release" status.
Emergency Close All Door	Click this button to make a force close on all the door(s) remotely and the door(s) cannot be accessed normally.
Fire Alarm Detection ON	Click this button to activate the "Fire Alarm Detection" function and the door(s) state will display "on".
Fire Alarm Detection OFF	Click this button to deactivate the "Fire Alarm Detection" function and the door(s) state will display "off".
Alarm OFF	Click this button to deactivate all the Alarms already triggered.

♦ Event Handle

Select "Event Handle" on the left side of the Main Window, you'll see the "Event Handle" screen as below:

Event Handle

	Hard Alarm	Soft Alarm1	Soft Alarm2	IP Camera
Latched Time(Second)	0	0	0	0
Event				
Unregistered User	0	0	0	0
Deactivated User	0	0	0	0
Not Allowed Door	0	0	0	0
Time Zone Violation	0	0	0	0
Expired User	0	0	0	0
Anti Pass Back Violation	0	0	0	0
Door open too long	0	0	0	0
Door Intruded	0	0	0	0
Duress Alarm On	0	0	0	0
Fire Alarm On	0	0	0	0

♦ Illustration of Event Handle

► Event Type				
z zvene zype	Set a latched time (0~65535 seconds) for Hard Alarm/Soft Alarm 1/Soft Alarm 2/IP Camera event trigger.			
	Hard Alarm: Set Event to Trigger Hard Alarm Hard Alarm Latched Time (sec, Max 65535: 0 means unlimited)			
	Unregistered User □ Deactivated User □ Not Allowed Door □ Time Zone Violation □ Expired User □ Anti Pass Back Violation □ Door open too long □ Door Intruded □ Duress Alarm On □ Fire Alarm On □ Set			
	Soft Alarm 1 / Soft Alarm 2 : Soft Alarm1			
Latched Time	Latched Time 0 (sec,Max 65535 : 0 means unlimited) Unregistered User Deactivated User Not Allowed Door Time Zone Violation Expired User Anti Pass Back Violation Door open too long Door Intruded Duress Alarm On Fire Alarm On			
	Soft Alarm2			
	Latched Time 0 (sec,Max 65535 : 0 means unlimited) Unregistered User Deactivated User Not Allowed Door Time Zone Violation Expired User Anti Pass Back Violation Door open too long Door Intruded Duress Alarm On Set			
	IP Camera: Even trigger type from IP Camera			
	Unregistered User Deactivated User Not Allowed Door Time Zone Violation Expired User Anti Pass Back Violation Door open too long Door Intruded Duress Alarm On Set			
	1 \ It will be listed in the "Drop Down Menu". When it's selected and the user unregistered, one unregistered record will be shown on the "Access			
Unregistered User	Log "screen (referring to the sample as below); if the event level equal to or higher than the "Alarm Trigger Level", the Relay will be triggered and the			
	E-mail will alert when "E-mail Alerts "is configured and one alert e-mail will be sent out.			
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by			
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security Bypass" screen of "Remote Control" function, default level = 0, referring to the below picture:			

	1 \ It will be listed in the "Drop Down Menu". When it's selected and the
Deactivated User	user deactivated, one "Deactivated" message will be recorded and shown on the "Access Log" screen (referring to the example as below); if the event level equal to or higher than the "Alarm Trigger Level", the Relay will be triggered and the E-mail will alert when "E-mail Alerts" is configured and one alert e-mail will be sent out. 2 · When the "Latched Time: 0", the alert can only be lifted/stopped by clicking "Alarm OFF "button on the "Door Status Monitoring/Security Bypass" screen of "Remote Control" function, default level = 0.
Not Allowed Door	1 ` It will be listed in the "Drop Down Menu". When it's selected and the user's "Group" setting different from the Door Settings, one "DISALLOWED DOOR" message will be recorded and shown on the "Access Log "screen; if the event level equal to or higher than the "Alarm Trigger Level", the Relay will be triggered and the E-mail will alert when "E-mail Alerts "is configured and one alert e-mail will be sent out. (referring to below examples of user's Group setting and Door setting) (steps: Access Log→Click the User ID→Enter the "User RECORD" screen to modify the configuration of "Group") 2 ` When the "Latched Time: 0", the alert can only be lifted/stopped by clicking "Alarm OFF "button on the "Door Status Monitoring/Security Bypass" screen of "Remote Control" function, default level = 0.
Multi-Badge Violation	1 \ It will be listed in the "Drop Down Menu". When it's selected and the "Multi-Badge" verification failed, one "(1)DOUBLE REJ" message will be recorded and shown on the " Access Log" screen (referring to the example as below); if the event level equal to or higher than the" Alarm Trigger Level", the Relay will be triggered and the E-mail will alert when "E-mail Alerts "is configured and one alert e-mail will be sent out. 2 \ When the "Latched Time: 0", the alert can only be lifted/stopped by clicking "Alarm OFF "button on the "Door Status Monitoring/Security Bypass" screen of "Remote Control" function, default level = 0.
Time Zone Violation	1 · It will be listed in the "Drop Down Menu". When it's selected and the user's "Group" setting different from the Door Settings, one "(1)Open Time Error "message will be recorded and shown on the Access Log "screen (referring to the example as below); if the event level equal to or higher than the" Alarm Trigger Level", the Relay will be triggered and the E-mail will alert when "E-mail Alerts "is configured and one alert e-mail will be sent out. 2 · When the "Latched Time : 0", the alert can only be lifted/stopped by clicking "Alarm OFF "button on the "Door Status Monitoring/Security Bypass" screen of "Remote Control" function, default level = 0.

	1 It will be lived in the "Down Down Many" Wiley it's related and the
	1 · It will be listed in the "Drop Down Menu". When it's selected and the
	user's "Expiry Date" overdue, one "(1)EXPIRED "message will be
	recorded and shown on the Access Log "screen (referring to the example as
	below); if the event level equal to or higher than the "Alarm Trigger Level",
Expired User	the Relay will be triggered and the E-mail will alert when "E-mail
	Alerts "is configured and one alert e-mail will be sent out.
	2 · When the "Latched Time : 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 0.
	1 · It will be listed in the "Drop Down Menu". When it's selected and the
	doors with "Anti Pass Back Level "configuration, one "(1)ANTI_PB
	REJ "message will be recorded and shown on the Access Log "screen
	(referring to the example as below); if the event level equal to or higher
Anti Pass Back	than the "Alarm Trigger Level", the Relay will be triggered and the E-mail
	will alert when "E-mail Alerts "is configured and one alert e-mail will be
Violation	sent out.
	2 · When the "Latched Time : 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 0.
	X Only 1 Door (2 way) is supported with this function.
	1 · It will be listed in the "Drop Down Menu". When it's selected and the
	door closes over the time set after the user card being scanned, one
	"(O)Open too long "message will be recorded and shown on the Access
	Log "screen (referring to the example as below); if the event level equal to
Door open too	or higher than the "Alarm Trigger Level", the Relay will be triggered and
long	the E-mail will alert when "E-mail Alerts "is configured and one alert
	e-mail will be sent out.
	2 · When the "Latched Time : 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 0.
	1 · It will be listed in the "Drop Down Menu". When it's selected and the
	door is accessed forcibly and abnormally, one "(O) DOOR INTRUDED "
	message will be shown on the Access Log "screen (referring to the example
	as below); if the event level equal to or higher than the "Alarm Trigger
Door Intruded	Level", the Relay will be triggered and the E-mail will alert when "E-mail
	Alerts "is configured and one alert e-mail will be sent out.
	2 · When the "Latched Time : 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 4.
	Dypuso Selection Remote Control Tunction, default level – 7.

	1 \ It will be listed in the "Drop Down Menu". When it's selected and the
	"Duress Alarm "of a door is triggered by the user (note : you have to key in
	the "Anti Duress Password" and press "ENT "before scanning the user
	card), one "ANTI DURESS" message will be shown on the Access
Dunga Alama On	Log "screen; if the event level equal to or higher than the "Alarm Trigger
Duress Alarm On	Level", the Relay will be triggered and the E-mail will alert when "E-mail
	Alerts "is configured and one alert e-mail will be sent out.
	2 · When the "Latched Time: 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 4.
	1 · It will be listed in the "Drop Down Menu". When it's selected and if
	the "Fire Alarm "is triggered, one "FIRE ALARM" message will be
	recorded and shown on the Access Log "screen; if the event level equal to
	or higher than the "Alarm Trigger Level", the Relay will be triggered and
Fire Alarm On	the E-mail will alert when "E-mail Alerts "is configured and one alert
	e-mail will be sent out.
	2 · When the "Latched Time : 0", the alert can only be lifted/stopped by
	clicking "Alarm OFF "button on the "Door Status Monitoring/Security
	Bypass" screen of "Remote Control" function, default level = 5.

♦ Multi Badge Group

Select and Click "Multi Badge Group" on the left side of the Main Window, you'll see the "Multi Badge Group" screen as below:

Multi Badge Group

Multi Badge Group	User ID 1	User ID 2	User ID 3	
1.				
2.				
3.				
4.				
5.				
6.				
7.				
8.				
9.				
10.				
set				

♦ Illustration of Multi Badge Group

► Multi Badge Group	
Multi Badge Group	Max. 10 Groups to be set.
User ID 1	Enter the User ID 1 for Multi Badge Group.
User ID 2	Enter the User ID 2 for Multi Badge Group.
User ID 3	Enter the User ID 3 for Multi Badge Group.
Set (button)	Save all the configurations.

> Tools

♦ IP Camera

Select "IP Camera" on the left side of the Main Window, you'll see the "IP Camera" screen as the following example:

IP Camera(IP)	PORT	TYPE	username (30 Char. Max)	password (30 Char. Max)	IN Camera ID OUT (1~16) (Camera ID (1~16)	Door 1	Door 2
1. 0.0.0.0	80	VIVOTEK IP7133/7330 ✓]			
2. 0.0.0.0	80	VIVOTEK IP7133/7330 ✔						×
		Set Refresh						

♦ Illustration of IP Camera

► IP Camera	
IP Camera 1	Enter the IP address of IP Camera 1 to be lined.
IP Camera 2	Enter the IP address of IP Camera 2 to be lined.
Door 1	Display the captured and the most updated picture of Door 1.
Door 2	Display the captured and the most updated picture of Door 2.
Set (button)	Save all the configurations.
Refresh (button)	Refresh the WEB page of IP Camera.

♦ Backup

MX60-D system can be backup for restore to system again by selecting:

Database/User Data/User list, as below:

Backup

Tips:

This command will export the User Registry data for backup purpose.

● Database(database.cfg) ○ User Data(userdata.cfg) ○ User List(userlist.txt)

BACKUP

♦ Restore

MX60-D system can be backup and restore to MX60-D again. Only Database/User List available.

RESTORE / IMPORT

Select a File to Restore / Import: ②覧… ② Database(database.cfg/userdata.cfg) ① User List(userlist.txt) (It may takes few minutes to restore the database.) Restore

♦ Reboot

Select "Reboot" on the left side of the Main Window, you'll see the "Reboot System" screen as below:

Reboot System

REBOOT

♦ Illustration of Reboot

▶Button	
Reboot	Reboot the MX60-D2, similar to warm boot a computer.

♦ Upgrade Firmware

Select "Upgrade FIRMWARE" on the left side of the Main Window, you'll see the "FIRMWARE UPGRADE" screen as below:

FIRMWAVE UPGRADE

Warning: Upgrade must NOT be interrupted	
Please select a file to upgrade: 瀏覽	UPGRADE
	_

♦ Illustration of Upgrade Firmware

► Steps

Press button "Browse" to search your firmware to be upgraded.

Press button "Upgrade" to execute the firmware upgrade action.

► Note

Please upgrade the "System Code" first then upgrade "WEB code".

♦ Reset

Select "Reset" on the left side of the Main Window, you'll see the "Reset" screen as below:

Reset

☐ User Data ☐ Access Logs ☐ Group ☐ Time Zone ☐ Time Set ☐ Holiday SELECT ALL DELETE	☐ System Logs
Reset System to Factory Default - Factory Default	

♦ Illustration of Reset

▶ Data Reset		
User Data	Tick the box before "User Data" and Click "Delete" button to	
	delete all the User Data.	
Access Log	Tick the box before "Access Log" and Click "Delete" button	
	to delete all the Access Logs.	
Group	Tick the box before "Group" and Click "Delete" button	
	to delete all the Groups.	
Time Zone	Tick the box before "Time Zone" and Click "Delete" button	
	to delete all the Time Zone configurations.	
Time Set	Tick the box before "Time Set" and Click "Delete" button	
	to delete all the Time Set configurations.	
Holiday	Tick the box before "Holiday" and Click "Delete" button	
	to delete all the Holiday configurations.	
System Logs	Tick the box before "System Logs" and Click"Delete" button	
	to delete all the System Logs.	
▶Button		
Select All	Tick the box before above item.	
Delete	Delete above item(s) selected.	
Steps:		
1 \ Tick the item	above to be deleted.	
2 · Click button "Delete".		
► Reset System to Factory Default		
Factory Default	Execute this command to restore the system back to the factory	
	default.	